

TERMS AND CONDITIONS

- 1) Monthly visit of service engineer is required
- 2) Water sample of Boiler and feed water (Two samples) need to be collected for analysis and report need to be submitted. Suggestions and corrections if any shall be brought to the notice of the officers. The quality of water after treatment shall adhere to acceptable limits.
- 3) Stock status of chemicals need to be monitored and should remind the concerned officer if the stock is not sufficient for one month
- 4) Training need to be given to the operators on chemical usage
- 5) Chemicals supplying for treatment should have MSDS, Toxicology or food grade certificate.
- 6) The quoted rate shall be inclusive of freight charges and exclusive of GST

PAYMENT CONDITION:

- Payment immediately

LIST OF APPROVED MAKE

Thermax/Ion exchange/Nalaco/Kimberlite

